


Note for the installation:

It is absolutely necessary to have a minimum maintenance- and service area of 60 cm around the CHPP at the installation site, which is freely accessible. A further condition is a clearance of 2,0 m height above the installation site and a plane surface with sufficient loading capacity. Please consider also our installation- and operation conditions!

Not considered minimum distances cause more difficult working conditions, followed by significantly higher costs.

Item number	Part number	Description				
	sb22 200 000 BHKW	smartblock 22 dimensions CHPP				
 KW ENERGIE	Material	Weight	Date	Name	Scale	Revision
		997,95 kg	25.08.2016	A. Dünhuber	1:25	
Note:	Testing				Size	Sheet of
CAD-drawing, all rights reserved, Observe protection notices in accordance with DIN ISO 16016		Series releasing			A4	1 1